

Corrigendum-I

In reference to the e-Tender no. e - Tender/Hartron/Proc/2016-17/54 (invent id 29620) for supply of 56 no.2 KVA Online UPS with 1 hour battery backup under buy back scheme on behalf of Punjab & Haryana High Court, Chandigarh. After pre-bid meeting following amendments had been incorporated:-

S#	Clause of RFP before Pre-bid	Revised Clause after Pre-bid
1.	These items are to be supplied at various Courts in the state of Haryana & Punjab within 30 days from the date of placement of Purchase Order. (Page no. 9 Clause 2, Page no. 36 Annexure-10)	The delivery period may be read as 42 days (6 weeks) from the date of placement of the purchase orders.
2.	Battery Make - Exide/Quanta/Hi Power or JIS C8702 approved. (Page no. 12 Clause no. 4 of Minimum Technical Specifications)	The battery make should be Exide/Quanta (VRLA SMF battery).
3.	None of the components and sub-components are declared "End-of-sale" by the respective OEM in next three (3) years as on date of submission of Bid. (Page no. 30, Annexure-6 - Undertaking for honoring warranty: S. No-3)	In "Annexure - 6 - Undertaking for honoring warranty" the warranty may please be read as 5 years instead of 3 years from the date of installation/commissioning of the UPS systems.
4.	We would provide on-site maintenance of the installed system for a period of three (3) years from the date of commissioning of the system within the price quoted by us in the Commercial Bid. (Pg. no. 30, Annexure-6 - Undertaking for honoring warranty: S. No-5)	
5.	BIS certifications (Technical Specification)	The BIS Certification is mandatory for UPS System.

Note :- The mandatory replacement of the batteries after 2^{1/2} Years for 5 years warranty and support for 02 KVA Online UPS System.

- The last date for submission of bid is extended upto 20.01.2017 by 2:30 P.M.
- All other terms & conditions will remain same as per standard document and released corrigendum(s).

Managing Director