



**OFFICE OF EXECUTIVE ENGINEER ELECT. DIVN. PWD B&R
GURUGRAM**

**pwd-eeed-gurgaon@hry.nic.in
0124-2320874**

**CORRINGENDUM FOR TENDER NO-64024 (CONSTRUCTION OF HANGER AT
CIVIL AIR STRIP BACHHOD NARNAUL (PDG. FIRE FIGHTING SYSTEM AND
FIRE SAFETY)**

1. Item no-6 of BOQ makes will be **ZOLOTO, KARTAR, LEADER** instead of makes manentioned in BOQ.
2. Item no-8 of BOQ "Fire brigade inlet will be of 100 mm dia instead of 150 mm dia".
3. Item no-9 of BOQ " Head of main pump will be of 50 metre instead of 60 metre".
4. Item no-19 of BOQ " Fire extinguisher will be of "SAFEX/ MINIMAX/ EXFLAME" make.
5. Item no-26 of BOQ " Water tank will be of PVC of 10,000 litre capacity of make **SINTEX / SHEETAL / DIPLAST**"

Ah
Executive Engineer,
Electrical Division PWD B&R
Gurugram
(Phone: 0124-2320874)
(For and on behalf of Governor of Haryana)

Endst No: -

203799

Dated: -

06/12/17

Copy is forwarded to the following for information and necessary action: -

1. ✓ Superintending Engineer. Elect. Circle PWD B&R Branch, Karnal.
2. All Executive Engineer, Elect. Divn. PWD B&R Branch, in Haryana.
3. All Sub Divisional Engineer under Elect. Divn. Gurugram.
4. All Electrical Contractors in relevant category.
5. Dy. Supdt./HDM/Accountant/Notice Board.

DA/Nil

SA
Executive Engineer,
Elect.Divn. PWD B&R Br.,
Gurugram